

Minutes of the Pre Bid Meeting

Pre-Bid meeting was held on 17/03/2023 at 11 AM through online mode via link provided in the instruction to the bidders for the tender nos. 23RFQ0002, 23RFQ0003 and 23RFQ0004. The details of the participants is given below.

Sl. No	Tender No	Description of the Tender	Name of the Participant
1	23RFQ0002	Supply and installation of rapid sand filters and glass media filter at Kanyakumari District, Tamil Nadu	1. Mr. R A Rajkumar, M/s. Rainbow Solutions, Chennai, Tamil Nadu
2	23RFQ0003	Supply of 7.5 HP pumps and motors at Kanyakumari District, Tamil Nadu	No participant was present
3	23RFQ0004	Supply of 10 HP pumps and motors at Kanyakumari District, Tamil Nadu	No participant was present

The details discussion relating to tender no 23RFQ0002 is given below.

Sl. No	Query raised	Reply from RGCA
1	Is the rapid sand filter requirement for top or front mounting model.	Spherical shaped rapid sand filter with top mounted multi-port valve.
2	What about the need of manhole for rapid sand filter.	Not needed.
3	Kindly provide details of the platform for installation at project site	Civil platform shall be made by RGCA, upon which installation needs to be done.
4	Does the scope includes supply, fixation, installation of the pipes and fittings for the rapid sand filters.	Scope of the bidder includes supply, installation of pipes and fittings.
5	Can pumps made of Stainless Steel be supplied for the rapid sand filters.	No. Pumps made with duplex steel alone will be accepted. This is considering the high salinity sea water at the project site.

Based on the above discussion the tenders may be submitted on or before the dates specified in the tender document.

The meeting ended with a thank you note to all participants and officials.